

CITY OF CUYAHOGA FALLS, OHIO

June 3, 2022

**ADDENDUM NO. 1**

To the Drawings and Specifications For

***EXTENSION OF WATER MAIN IN AKRON-CLEVELAND ROAD***

TO ALL BIDDERS:

This Addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become a part of the contract documents as follows:

- Restrained joints are only required for fittings, bends, hydrants, and where PVC pipe is connected to ductile iron pipe.
- Installation of new water main shall include tracer wire and marking tape. Tracer wire shall be AIS certified copper clad steel "CCS", located alongside the pipe at the 3 or 9 o'clock positions. Connectors shall have non-drying gel. The tracer wire shall be properly grounded according to industry standards, and include test stations at all hydrant locations, and at the beginning and end of the project. Marking tape shall be located on top of no. 57 limestone cover stone.
- All work detailed above in this addendum is considered incidental to the cost of the water main.

**END OF ADDENDUM #1**

# **Acknowledgement of Receipt of Addendum No. 1**

## ***EXTENSION OF WATER MAIN IN AKRON-CLEVELAND ROAD***

**PLEASE REPLY IMMEDIATELY via e-mail @ [engineering@cityofcf.com](mailto:engineering@cityofcf.com), to acknowledge receipt of this addendum.**

**Sign and print your name below on this acknowledgement sheet.**

Addendum No. 1 received by:

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Date

\_\_\_\_\_  
Print Name

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Contact Email