

CITY OF CUYAHOGA FALLS, OHIO

May 9, 2024

ADDENDUM NO. 2

To the Specifications For

***The Replacement, Training, and Design of the
Cuyahoga Falls Electric SCADA Systems.***

TO ALL BIDDERS:

This Addendum supplements and amends the original specifications for and shall be taken into account in preparing proposals and shall become a part of the contract documents as follows:

- Question Clarification #'s 17 - 40
- Current Network Architecture Model Numbers
- Eleven (11) Supporting Images of Existing Equipment

END OF ADDENDUM #2

Acknowledgement of Receipt of Addendum No. 2

The Replacement, Training, and Design of the Cuyahoga Falls Electric SCADA Systems.

PLEASE REPLY IMMEDIATELY via e-mail @ electricdept@cityofcf.com, to acknowledge receipt of this addendum.

Sign and print your name below on this acknowledgement sheet.

Addendum No. 2 received by:

Signature

Date

Print Name

Company Name

Contact Email

**CUYAHOGA FALLS ELECTRIC SYSTEM - SCADA RFP
ADDENDUM #2**

Question #	Document	Section/Description	Queries/Clarifications	CFED Responses
17	Cuyahoga Falls – New System Requirements	General	<p>Previous questions asked if all connections to the SCADA Servers are TCP/IP, and the response was yes.</p> <p>The SCADA Servers are TCP/IP to the local SCADA Network Ethernet Switch, but all communications to Substation RTUs are currently serial over fiber and are converted to/from TCP/IP at the Lantronix Server. Is this current communications format to remain in place as-is?</p>	Yes, to remain, if possible. The SCADA servers connect to the RTUs through a serial server, then that serial server connect to fiber media converters, then the communications convert back to serial over copper at the substations. If the vendor wanted to change this then they should include the Ethernet media converters in their quote.
18	Cuyahoga Falls – New System Requirements	General	Will CFED make available a detailed point list and current point mapping to each port of each RTU? Or is bidder expected to pull that data as part of the project? If so, will CFED make available a copy of ConfigWiz or the latest version of configuration software for the RTU?	Yes, after RFP awarded, the vendor chosen can get the point list and mapping.
19	Cuyahoga Falls – New System Requirements	The new SCADA system should allow Cuyahoga Falls to pull the same set of on-demand and scheduled reports that exist on the current system and should allow for direct Excel integration to query archived data.	Please provide a listing of the existing reports so a quantity can be established.	Approximately 10
20	Cuyahoga Falls – New System Requirements	In addition to replacing the existing main SCADA system Cuyahoga Falls wants to integrate the functionality of another existing system that reads data from Siemens reclosers using the 61850 GOOSE protocol and can send manual controls to the reclosers. By the conclusion of the implementation, the new SCADA system should replace the core functionality of this recloser-reading system, in addition to replacing the existing SCADA system.	<p>Q1: Is the intent to take the Siemens HMI out of the loop and have the SCADA system directly read the reclosers for status and to issue manual controls?</p> <p>Q2: May we expect that the automated control portions, both recloser sectionalizing/restoration and voltage regulation will still be conducted in a peer fashion between the devices, requiring no interface with the SCADA?</p> <p>Q3: Will the Siemens computer remain in place for DIGSI, configuration of the devices, and to maintain the storage of COMTRADE files?</p>	Q1: Yes, if possible Q2: Yes Q3: Yes, it can remain in place for DIGSI, configsm and COMTRADE files.
21	Cuyahoga Falls – New System Requirements	General	IS it possible to make a site visit in order to view the current system? Please advise.	Yes
22	Cuyahoga Falls – New System Requirements	Legal Notice	May the proposals be delivered electronically or are they expected to be hand delivered?	Must be mailed or hand delivered. Electronically will not be accepted.
23	Cuyahoga Falls – New System Requirements	System Architecture	<p>Is the system architecture intended to stay the same?</p> <p>Assumption is City IT will be responsible for the current network design including switches, firewall, and cybersecurity issues for the network. Please confirm.</p>	Intended to stay the same unless vendor's standard configuration differs greatly from current architecture. Meeting would be needed to discuss. City's IT department would be responsible for maintaining the network.
24	Cuyahoga Falls – New System Requirements	Unless otherwise directed by Cuyahoga Falls, the new SCADA system should perform time-synchronization of the existing RTUs using DNP3, and those RTUs should perform time-synchronization of the IEDs they read using DNP3.	Does the current clock support NTP/SNTP, IRIG-B, or other? Please clarify clock output capabilities.	Per the Arbiter manual, it does support NTP. 1903B Arbuter Clock
25	Cuyahoga Falls – New System Requirements	All points that exist in the current system must be configured and tested in the new system. In the current system, Cuyahoga Falls utilizes 79 calculations and 16 command sequences that produce calculated values. These calculations mainly involve basic operations such as addition, multiplication, and counting. All existing calculations must be replicated in the new SCADA system to ensure their continued functionality.	Will the City provide the calculation and sequence configurations to be used in integration of the new system?	The implementor should pull these from the existing system.
26	Cuyahoga Falls – New System Requirements	Cuyahoga Falls has not observed any issues with limits and reasonability thresholds for any existing SCADA points, so the existing point limits and thresholds should be used on the new system.	Will the City provide the limits and thresholds for the existing points to be used in the new system?	The implementor should pull these from the existing system.
27	Cuyahoga Falls – New System Requirements	Additionally, Cuyahoga Falls will also require a quote for an annual block of 40 hours to be used in assisting with the management of the system. This support should be quoted as both 3-year and 5-year options.	Are the 3-year and 5-year options only for the "annual block of 40 hours"?	Yes, and for the 24x7 tech support, if available.


**CUYAHOGA FALLS ELECTRIC SYSTEM - SCADA RFP
ADDENDUM #2**

Question #	Document	Section/Description	Queries/Clarifications	CFED Responses
28			Please confirm how many workstations will be used and the CPU that they have.	<p>Workstations: Total 8 Product name: HP EliteDesk 705 G5 Desktop Mini PC CPU: AMD Ryzen 5 3.3GHz Memory: 8 GB DDR4-2666 MHz RAM (1 x 8 GB) Internal drive: 256 GB PCIe® NVMe™ TLC M.2 SSD Ports: Front 1 headphone; 1 headset connector; 1 SuperSpeed USB 5Gbps signaling rate; 1 SuperSpeed USB 5Gbps signaling rate (charging); 1 SuperSpeed USB Type-C® 10Gbps signaling rate (charging) [6,9,10,11,12,13,36] Rear 1 external antenna connector; 1 power connector; 1 RJ-45; 3 DisplayPort™ 1.2; 4 USB 3.1 Gen 1 Additional 1 DisplayPort™ Operating System: Windows 11 Pro 22H2</p>
29			Please confirm how many Cuyahoga Falls Electric Service personnel would attend vendor provided admin and engineering training.	3
30			<p>Please provide the list of specifications for the “newer existing server” that Cuyahoga Falls Electric Service would like to re-use.</p> <p>a) Additionally, what would Cuyahoga Falls Electric Service like to use this for (i.e. one of the host servers, etc.)? b) If the vendor agrees to use this server, would Cuyahoga Falls Electric Service be willing to ship it along with the other Hardware to the vendors staging facility?</p>	See answer below. A) One of the host servers. B) Possibly send redundant server to vendor.
31			What is the current make, model, and version of the existing SCADA system?	Cuyahoga Falls’ QEI SCADA system operates on two servers located in the SCADA room of the Electric Department building, referred to as CUYA and CUYB, running the OpenVMS operating system. The CUYA server is an HP RX2800 i6 server installed in 2018 and the CUYB server is an HP RX2660 installed in 2012. The system can be accessed from a desktop located in the SCADA room, and from at least 8 other workstation desktops in the building
32			<p>What RDBMS does Cuyahoga Falls Electric Service currently use?</p> <p>a) How many months/years of data must be migrated to the new system?</p>	Database is SQL Express, QEI Enterprise Data Manager and minimum of 4 years.
33			What is the model and version if the SICAM HMI that is used with the Siemens Automatic Transfer System?	Addendum 1 PDF "Siemens Automatic Transfer System"
34			How many concurrent web-view only users would be needed?	10
35			<p>Could Cuyahoga Falls Electric Service elaborate on what the “Annual block of 40 hours to be used in assisting with the management of the system” would look like?</p> <p>a) Additional details of specific tasks/requirements for this would be greatly appreciated.</p>	Modifications to screens, database cleanup, calculation assistance.


**CUYAHOGA FALLS ELECTRIC SYSTEM - SCADA RFP
ADDENDUM #2**

Question #	Document	Section/Description	Queries/Clarifications	CFED Responses
36			<p>Is Secure ICCP required?</p> <p>a) If so, how many total ICCP connections/associations are there to other entities/systems?</p>	No
37			<p>Regarding the project schedule, does Cuyahoga Falls Electric Service have any expectations or drivers that pertain to key dates/milestones and/or overall project duration? If so, please elaborate.</p>	<p>Our new electric building will be completed November 2024, so implantation would be as soon as possible in new building. Completion would be expected mid-2025.</p>
38			<p>Please expand on the requirements for networking configuration (e.g., firewall rules, active directory setup, etc.)</p>	<p>Combination of bidder system requirements and then City of Cuyahoga Falls IT department could review and make changes as needed.</p>
39			<p>Will Cuyahoga Falls Electric Service allow a follow-up round of questions to be submitted from vendors based on responses received from this round if required?</p>	Yes
40			<p>Would Cuyahoga Falls Electric Service be open to a joint proposal, and issuing separate contracts for software licensing and implementation services?</p>	No


Electric Department Building



To rest of City network



- Serial
- Ethernet
- Fiber



Home View Edit Map

Zoom Box Zoom In Zoom Out Pan View GoTo Device GoTo XY Coord GoTo Line Section

Previous View Next View Default View Map Views Layers Birdseye Full Screen

List Notes Add Notes Modify Notes Delete Notes Cancel Windows Window



CUYAHOGA FALLS ELECTRIC SYSTEM

AMERICAN MUNICIPAL UTILITIES
57.4 DEGREES

SUB 1	NEW SUB 5	SUB 9	SUB 13	FEEDER % LOAD	DEMAND READINGS
SUB 2	SUB 6	SUB 10	SYSTEM	COMM LINES	LOAD READINGS
SUB 3	SUB 7	VALLEY	SUMMARY	RECLOSERS	SCADA EVENTS
SUB 4	SUB 8	THEISS	OLD SUB 5		

SYSTEM TOTAL

45.97 LAST

46.41 TODAY AT 923

68.00 M-T-D ON 5 / 2 AT 1751

68.00 Y-T-D ON 4 / 29 AT 1816



**CUYAHOGA FALLS
ELECTRIC SYSTEM**
AMERICAN MUNICIPAL UTILITIES

4 - 8 23KV LINE

- MAIN MENU
- SYSTEM
- SUB 4
- SUB 8

SUB 4

4-VCB-89 **CLOSED**

RELAY STATUS **ONLINE**

RELAY HEALTH CHECK **NORMAL**

RELAY COMMUNICATIONS **NORMAL**

TOTAL RECEIPT FAILURE **NORMAL**

FIRMWARE MISMATCH **NORMAL**

87 DIFFERENTIAL TRIP **NORMAL**

87 FAULT PHASE A **NORMAL**

87 FAULT PHASE B **NORMAL**

87 FAULT PHASE C **NORMAL**

87 GROUND FAULT **NORMAL**

50/51 OVERCURRENT TRIP **NORMAL**

50/51 PICKUP PHASE A **NORMAL**

50/51 PICKUP PHASE B **NORMAL**

50/51 PICKUP PHASE C **NORMAL**

50/51 PICKUP GROUND **NORMAL**

BACKUP RELAY STATUS **ONLINE**

BACKUP HEALTH CHECK **NORMAL**

67/67N TRIP **NORMAL**

4-9 LOCKOUT PICKUP **NORMAL**

	CURRENT	VOLTAGE
A	126	24.227
B	121	24.283
C	121	24.241
N	6	

SUB 8

8-VCB-45 **CLOSED**

RELAY STATUS **ONLINE**

RELAY HEALTH CHECK **NORMAL**

RELAY COMMUNICATIONS **NORMAL**

TOTAL RECEIPT FAILURE **NORMAL**

FIRMWARE MISMATCH **NORMAL**

87 DIFFERENTIAL TRIP **NORMAL**

87 FAULT PHASE A **NORMAL**

87 FAULT PHASE B **NORMAL**

87 FAULT PHASE C **NORMAL**

87 GROUND FAULT **NORMAL**

50/51 OVERCURRENT TRIP **NORMAL**

50/51 PICKUP PHASE A **NORMAL**

50/51 PICKUP PHASE B **NORMAL**

50/51 PICKUP PHASE C **NORMAL**

50/51 PICKUP GROUND **NORMAL**


	CURRENT	VOLTAGE
A	0.00	0.00
B	0.00	0.00
C	0.00	0.00
N	0.00	

SYSTEM LOAD SUMMARY

MAIN MENU

VOLTAGE

FEEDER	STATUS	MW	% LOAD	∅ A	∅ B	∅ C	∅ N	%PF	FEEDER	STATUS	MW	% LOAD	∅ A	∅ B	∅ C	∅ N	%PF
SUB 1									SUB 7								
101	79	0.62	16.5	100	79	84	28	98	701	79	0.00	0.0	0	0	0	0	0
102	79	0.79	21.1	106	108	120	24	98	702	79	0.62	16.4	87	91	81	9	99
103	79	0.96	9.6	50	41	44	15	99	SUB 8								
104	79	3.21	32.1	154	144	146	18	98	801	79	0.30	12.2	43	46	45	8	96
SUB 2									802	79	0.50	19.9	69	77	61	25	98
201	79	0.18	3.6	24	22	30	14	99	803	79	0.31	6.2	17	17	9	7	99
202	79	1.00	20.1	159	138	125	42	97	804	79	1.20	24.0	66	66	47	25	-97
203	79	0.83	16.5	144	125	131	18	-82	SUB 9								
204	79	0.39	7.9	67	73	57	28	-83	901	79	0.66	13.2	34	33	39	17	-88
SUB 3									902	79	1.40	28.0	60	77	72	14	94
301	79	0.40	7.9	59	54	53	21	99	923	79	0.00	0.0	0	0	0	0	0
302	79	1.11	22.2	148	161	174	70	-100	SUB 10								
303	79	0.69	13.9	95	114	81	38	-100	1001	79	1.46	19.4	66	67	70	0	98
304	79	0.59	11.9	79	85	93	20	-96	1002	79	1.68	22.4	84	92	79	0	89
323	79	7.68	33.8	182	196	209		1	VALLEY								
SUB 4									VALLEY #1	79	9.5	23.7	237	239	243	3	98
401	79	0.99	13.2	56	46	47	12	93	VALLEY #2	79	8.8	22.0	218	223	227	5	98
402	79	2.11	28.2	96	100	94	17	100	VALLEY #3	79	9.5	23.8	239	240	244	7	98
SUB 5									VALLEY #4	79	9.5	23.8	236	241	249	13	97
T1		1.02	7.7	52	46	52	7	99	THEISS								
T2		2.70	21.2	136	140	137	9	93	THEISS 9	79	0.6	1.4	11	14	17	0	100
501	79	0.57	6.7	26	19	32	13	-99	THEISS 3	79	6.3	15.8	151	153	163	19	96
502	79	0.51	6.3	26	25	22	16	94	SUB 13								
503	79	1.64	20.4	75	81	77	9	93	1301	79	0.55	6.6	17	33	30	18	-96
504	79	1.14	14.2	62	52	49	19	94	1302	79	1.20	13.9	55	57	55	18	99
SUB 6									SYSTEM		INSTANTANEOUS MW						
601	79	0.63	12.6	82	995	78	26	-97	VALLEY SUB		39.23						
602	79	0.87	17.4	121	120	114	32	-99	THEISS SUB		6.89						
603	79	0.28	7.5	52	52	57	19	-71	GENERATION		0.00						
604	79	1.57	41.8	233	230	226	17	92	TOTAL		46.12						



- Home
- Find a setting
- System
- Display
- Sound
- Notifications & actions
- Focus assist
- Power & sleep
- Storage
- Tablet
- Multitasking
- Projecting to this PC
- Shared experiences
- System Components
- Clipboard
- Remote Desktop
- Optional features
- About

About

Your PC is monitored and protected.

[See details in Windows Security](#)

Device specifications

HP Z1 Entry Tower G5

Device name	ELPC31
Processor	Intel(R) Core(TM) i5-9500 CPU @ 3.00GHz 3.00 GHz
Installed RAM	16.0 GB (15.8 GB usable)
Device ID	EBEEBF8D-5819-4222-BBC0-8E41A7D87517
Product ID	00330-53106-21064-AAOEM
System type	64-bit operating system, x64-based processor
Pen and touch	No pen or touch input is available for this display

Copy

Rename this PC

Windows specifications

Edition	Windows 10 Pro
Version	22H2
Installed on	9/11/2020
OS build	19045.4170
Serial number	MXL0361XHZ
Experience	Windows Feature Experience Pack 1000.19054.1000.0

Copy

[Change product key or upgrade your edition of Windows](#)

[Read the Microsoft Services Agreement that applies to our services](#)

[Read the Microsoft Software License Terms](#)

Support

Related settings

[BitLocker settings](#)

[Device Manager](#)

[Remote desktop](#)

[System protection](#)

[Advanced system settings](#)

[Rename this PC \(advanced\)](#)

[Get help](#)

[Give feedback](#)



Home View Edit Map

Zoom Box Zoom In Zoom Out Pan View GoTo Device GoTo XY Coord GoTo Line Section


Previous View Next View Default View Map Views Layers Full Screen

List Notes Add Notes Modify Notes Delete Notes Cancel Windows Window

SUBSTATION #3

MAIN MENU

SYSTEM




Home View Edit Map

Zoom Box Zoom In Zoom Out Pan View GoTo Device GoTo XY Coord GoTo Line Section

Previous View Next View Default View Map Views Layers Full Screen

List Notes Add Notes Modify Notes Delete Notes Cancel Notes Windows Window






Control one line System Screen

5/9/2024 9:26:52 AM

SIEMENS

AUTO MODE ON AUTOMATIC RESTORATION RESTORE VOLT. LIMIT CONTROL OFF SIMULATION OFF



VR1 Control	R5 Control	R1 Control	R2 Control	R4 Control	R3 Control	VR2 Control
MJ-4A CONTROL	REMOTE	REMOTE	REMOTE	REMOTE	REMOTE	PHASE PROCESSING
VLC MODE OFF	NO HOT LINE TAG	NO HOT LINE TAG	NO HOT LINE TAG	NO HOT LINE TAG	NO HOT LINE TAG	
PHASE A TAP	RECLOSING ON	RECLOSING ON	RECLOSING ON	RECLOSING ON	RECLOSING ON	
PHASE B TAP	AC POWER OK	AC POWER OK	AC POWER OK	AC POWER OK	AC POWER OK	
PHASE C TAP	BATTERY OK	BATTERY OK	BATTERY OK	BATTERY OK	BATTERY OK	
TAP UP ENABLED	NO LOCKOUT	NO LOCKOUT	NO LOCKOUT	NO LOCKOUT	NO LOCKOUT	
TAP DOWN ENABLED	GROUND TRIP ON	DIRECTION 1	DIRECTION 2	GROUND TRIP ON	DIRECTION 1	

SIMULATION ONE LINE>>