

**Cuyahoga Falls City Council**  
**Minutes of the Public Improvements Committee Meeting**  
**December 4, 2006**

**Members:** Jerry James, Chair  
Debbie Ritzinger  
Terry Mader

Mr. James called the meeting to order at 7:05 p.m. All members were present.

The minutes of November 20, 2006 were approved as submitted.

**Legislation Considered:**

Temp. Ord. A-149  
Temp. Ord. A-150

**Discussion:**

**Temp. Ord. A-149**

An ordinance authorizing the Director of Public Service to enter into a contract or contracts, according to law, for improvements to the storm and sanitary sewers on Jennings Avenue and Silver Lake Avenue, Phase II, and declaring an emergency.

Mr. James read A-149 (second reading). Mr. Demasi said that following the flood of 2004, the City identified the Oakwood/Jennings corridor as an area that needed improvements to the storm and sanitary system. Currently, the storm sewer flow along Silver Lake Boulevard from 10<sup>th</sup> Street to Oakwood, and along Oakwood from the cemetery to almost Graham Road, flows down the storm sewer along Victor Avenue. It eventually makes it to the 66" storm sewer on Jennings. During large storm events, this combined flow surcharges the Victor storm system and causes flooding. This two-phase project will intercept the Oakwood flow south of Victor and direct it down a new storm sewer on Jennings, thus providing relief to the Victor system. Phase I has been installed. In Phase II, the new storm sewer on Jennings will be extended to Oakwood and Silver Lake.

*The committee recommended bringing out Temp. Ord. A-149 for approval.*

**Temp. Ord. A-150**

An ordinance authorizing the Director of Public Service to execute a modification of the contract for the removal of contaminated soils and the implementation of a remedial action plan for a former waste oil underground storage tank located at 2560 Bailey Road, in the City of Cuyahoga Falls, and declaring an emergency.

Mr. James read A-150 (second reading). Mr. Demasi said that during the implementation of the Remedial Action Plan at the service center waste oil tank location, additional contaminated soils were encountered that had to be removed in accordance with BUSTR regulations.

***The committee recommended bringing out Temp. Ord. A-150 for approval.***

The meeting adjourned at 7:08 p.m.