CITY OF CUYAHOGA FALLS, OHIO

June 5, 2020

ADDENDUM NO. 1

To the Drawings and Specifications For

PORTAGE TRAIL SERVICE ACCESS DRIVE

TO ALL BIDDERS:

This Addendum supplements and amends the original Plans and Specifications and shall be taken into account in preparing proposals and shall become a part of the contract documents as follows:

- What is thickness of Item 20 Topsoil Stockpiled? Answer: 3 inches (3")
- Can a substitution be made for the area drains? Answer: Nyoplast drain with beehive grate is an acceptable substitution
- Replace Pages 4.1.1* & 4.1.2* with 4.1.1* and 4.1.2*Revised 6/5/20

On the day of bidding, June 10, 2020, bidders needing to drop off their bid packet should call <u>330-971-8180</u> and the packet will be accepted at either the Mayor's Court door or the Police Department entrance door.

END OF ADDENDUM #1

Acknowledgement of Receipt of Addendum No. 1

PORTAGE TRAIL SERVICE ACCESS DRIVE

PLEASE REPLY IMMEDIATELY via e-mail @ engineering@cityofcf.com, to acknowledge receipt of this addendum.

Sign and print your name below on this acknowledgement sheet.

Addendum No. 1 received by:		
,	Signature	Date
	5 N	
	Print Name	
	Company Name	